Kentucky Department for Environmental Protection Division of Waste Management Underground Storage Tank Branch 300 Sower Boulevard – Frankfort KY 40601 (502) 564-5981 FOR OFFICIAL USE ONLY – DO NOT WRITE IN THIS SPACE

## **DRAFT**

## **UST Annual Walkthrough Inspection**

Date Form Completed		1 1			-				
1. UST Facility Information									
Agency Interest Number (AI)									
UST Facility Name									
UST Facility Physical Address		Street Address:							
		City: County:					Zip Code: -		
		2. UST System Own	'						
UST System Owner Name									
UST System Owner Contact Information		Dhone: ( )	Alternate Phone: ( )						
		Phone: ( ) -	Aitem	ernate Phone: ( ) -					
		Email:							
<ol> <li>Annual Inspection Checklist         (The monthly walkthrough inspection is part of the annual walkthrough inspection and should be completed at the time of the annual inspection)     </li> </ol>									
Spill Prevention							Comments (Problem, Solution or Repair)		
Submersible Turbine Pump (STP) in Sump	Any water or prod	duct removed & properly disposed		Yes	□No	□ N/A			
	Sumps are free of cracks, holes, bulges, or other defects		s [	Yes	□ No	□ N/A			
	Sump lids, gaske	Sump lids, gaskets, & seals present & in good condition			☐ No	□ N/A			
	Sump Sensors properly mounted at the bottom of the sump			☐ Yes	☐ No	□ N/A			
		Manway covers at grade in good condition, does not touch sump cover, all bolts present			☐ No	□ N/A			
Other Tank-Top Sump	Any water or product removed & properly disposed			Yes	☐ No	□ N/A			
	Sumps are free of cracks, holes, bulges, or other defects			☐ Yes	☐ No	□ N/A			
	Sump lids, gaskets, & seals present & in good condition			] Yes	☐ No	□ N/A			
	Manway covers at grade in good condition, does not touch sump cover, all bolts present			☐ Yes	□ No	□ N/A			
All Other Sumps	Any water or product removed & properly disposed			☐ Yes	☐ No	□ N/A			
	Sumps are free of cracks, holes, bulges, or other defects			☐ Yes	☐ No	□ N/A			
	Sump lids, gasket, & seals present & in good condition			Yes	☐ No	□ N/A			
	Manway covers at grade in good condition, does not touch sump cover, all bolts present			Yes	□No	□ N/A			
Dispensers with Sumps	Any water or product removed & properly disposed			] Yes	☐ No	□ N/A			
	Sumps free of trash, debris, & used filters		Γ	☐ Yes	☐ No	□ N/A			
	Sumps are free of cracks, holes, bulges, or other defects			Yes	☐ No	□ N/A			
	Penetration fitting	enetration fittings intact & secured				□ N/A			
		Comments (Problem, Solution or Repair)							
Tank Gauge Stick	Tank gauge stick broken	s can be clearly read & are not warped	or [	] Yes	□No	□ N/A			

4. Certification								
☐ Check here if the person completing the form is the same as the operator named in the Certification below.								
Name of Person Completing Form			Date Completed	1 1				
Email			Phone Number	( ) -				
In accordance with 401 KAR 42:060, Section 1, confirmed or suspected releases, spills, and overfills, shall be reported immediately, in accordance with KRS 224.1-400(11), to the cabinet's 24-hour Emergency Response Line at (800) 928-2380 or (502) 564-2380.								
I certify that I have personally examined and performed the walkthrough inspections as described above for this UST facility as established in 40 C.F.R. 280.36. I further certify that the information in this document is true, accurate and complete.								
O. differential	Printed	Date	1 1					
Certification	Signature							
Check appropriate box:		☐ UST Owner ☐ UST Operator ☐ Combined Class A Operator & Class B Operator						
If you have questions on how to fill out this form please contact the cabinet at (502) 564-5981 or visit our web site at <a href="http://waste.ky.gov/ust">http://waste.ky.gov/ust</a> . For copies of facility records please visit <a href="http://eec.ky.gov/pages/openrecords.aspx">http://eec.ky.gov/pages/openrecords.aspx</a> or email <a href="mailto:DEP.KORA@ky.gov">DEP.KORA@ky.gov</a> .								